



Retlif Testing Laboratories

3131 Detwiler Road, Harleysville, PA 19438
215-256-4133 - Fax: 215-256-4130

CORPORATE OFFICE
795 Marconi Avenue
Ronkonkoma, NY 11779
631-737-1500 Fax 631-737-1497
(A NY Corporation)

BRANCH LABORATORIES
101 New Boston Road
Goffstown, NH 03045
603-497-4600 Fax 603-497-5281

WASHINGTON
REGULATORY OFFICE
703-533-1614 Fax 703-533-1612



EMC Test Report
On
Respironics, Inc.
Evergo Portable Oxygen Concentrator
Model Number: 900

Customer Name: Respironics, Inc.

Customer P.O.: 4500345073

Date of Report: January 28, 2008

Test Report No.: R-1130P

Test Start Date: November 19, 2007

Test Finish Date: December 20, 2007

Test Technician(s): J. Kavalusky, F. Civitello, R. Wilson, R. Reitz

Test Engineer: R. Reitz

Supervisor: R. J. Reitz

Report Prepared By: C. Lattieri

Our letters, procedures and reports are for the exclusive use of the customer to whom they are addressed and their communication or the use of the name of Retlif Testing Laboratories must receive our prior written approval. Our letters, procedures and reports apply only to the sample tested and are not necessarily indicative of the qualities of apparently identical or similar products. The letters, procedures and reports and the name of Retlif Testing Laboratories or insignia are not to be used under any circumstances in advertising to the general public. This test report shall not be reproduced, except in full, without the written approval of Retlif Testing Laboratories. This test report shall not be reproduced, except in full, without the written approval of Retlif Testing Laboratories.

Test Program Summary con't

Susceptibility Criteria:

In accordance with Section 3.6 of Respironics EMC test protocol.

Test Methods:

The test methods performed on the EUT and the corresponding test results are shown in Table 1.

Table 1 - Test Methods

Paragraph	Method	Test Results
6.1	CISPR 11, Conducted Emissions	Complied
6.2	CISPR 11, Radiated Emissions	Complied
6.3	IEC 61000-4-3, Radiated Immunity	Complied
6.4	RTCA/DO-160E Section 21, Category M, Conducted RF Emissions, 150 kHz to 30 MHz	Complied
6.5	RTCA/DO-160E Section 21, Category M, Radiated RF Emissions, 2 MHz to 6 GHz	Complied



Retlif Testing Laboratories

Report No. R-1130P